

Item	Buildings	Wight/Bldg	Number of		Percent
			Issues	Issue div 6.66	
1	A Bldg	6.66	0	5.66	84.98498
2	B Bldg, construction site	0	0	0	0
3	C Bldg	6.66	2	4.66	69.96997
4	D Bldg	6.66	1	5.66	84.98498
5	E Bldg	6.66	1	5.66	84.98498
6	300 new MPA Bldg	6.66	0	6.66	100
7	DNA Annex Bldg	6.66	1	5.66	84.98498
8	2000 Admin Bldg	6.66	2	4.66	69.96997
9	1000 Bldg	6.66	1	5.66	84.98498
10	500 Bldg	6.66	2	4.66	69.96997
11	600 Bldg	6.66	1	5.66	84.98498
12	900 Bldg	6.66	1	5.66	84.98498
13	3000 Bldg	6.66	1	5.66	84.98498
14	4000 Bldg	6.66	1	5.66	84.98498
15	5000 Bldg	6.66	0	6.66	100
16	6000 Bldg	6.66	0	6.66	100
Total Assigned Weight		100			1274.775 divide by 15 84.98498

FAS MNS is operational at 85%  
as of March 2023

Legend

Percent	# of Bldgs	Assigned wieght/ Bldg
100	15	6.666666667

Note: B Bldg is under construction



Supervisory	Trouble
Site 1 Panel 1 FS supervisory: fire tamper, bldg. 100 1fl. Sprinkler riser valve tamper	Site 1 Panel 1 Trouble: Sbus communication RA 2000 LRC
Site 1 Panel 2 FS supervisory: supervisory tamper sw MPA pump room sprinkler controller trouble	Site 1 Panel 2 FS trouble: waterflow sw Admin north sprinkler switch missing
Site 1 Panel 1 FS supervisory: supervisory sw AHC sprinkler control valve trouble	Site 1 Panel 1 Trouble unused Extra pt
E Bldg	Site 1 Panel 3 Trouble: det, photo duct Bldg. 100 roof top AHU duct supply missing
2000 Bldg	Site 1 Panel 2 FS trouble: water flow sw Admin south sprinkler waterflow open ckt.
500 Bldg	Site 1 Panel 1 Trouble ground fault RPS-1000 41 500
500/600 Bldgs	Site 1 Panel 1 Trouble: SLC loop shorted 5815XL 19 500/600/ca
A Bldg	Site 1 Panel 1 Trouble: notif Strobes bldg. a 06 open ckt.
900 Bldg	Site 1 Panel 1 Trouble: Notif. Speakers bldg. bldg. 900 02 open ckt.
C Bldg	Site 1 Panel 2 Trouble: Notif. Speakers bldg. C 03 open ckt.
D Bldg	Site 1 Panel 1 Trouble: Vbus input ECS-50 w 29 bldg D

1000 Bldg	Site 1 Panel 1 Trouble: Ground fault RFS 1000 42 Tech
1000 Bldg	Site 1 Panel 1 Trouble: Battery RPS-1000 34 LRC
DNA Bldg	Site 1 Panel 4 FS trouble: det-photo duct DNA clean corridor 124 missing